



*This project is co-financed by the European Union and the Republic of Turkey*

*Bu Proje Avrupa Birliđi ve Trkiye Cumhuriyeti tarafından finanse edilmektedir*

Technical Assistance for Better Air Quality by  
Transposing the Large Combustion Plants  
Directive (TR2010/0327.04-01/001)

# EuralEnergy

## New cogeneration plant

### Design Experience

By Silvio Arienti,

Process Director, Power Division, Amec Foster Wheeler





*This project is co-financed by the European Union and the Republic of Turkey*

*Bu Proje Avrupa Birliđi ve Trkiye Cumhuriyeti tarafından finanse edilmektedir*

Technical Assistance for Better Air Quality by  
Transposing the Large Combustion Plants  
Directive (TR2010/0327.04-01/001)

## Agenda

- ▶ Introduction
- ▶ Scope of AmecFW work
- ▶ Feasibility Study – Technical features
- ▶ Basic Design – Technical features
- ▶ Evolution of the Emission Regulation
- ▶ Impact of new Emission Limits on the Technical Design of the Plant
- ▶ Comparison Summary between the existing Oil boilers and the new CFB
- ▶ Economic Estimate and Schedule





This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Introduction

### ► Eurallumina:

- Company producing alumina (approx. 3,200 t/day) from bauxite
  - Recently acquired by RUSAL



- Alumina production is an energy intensive process, requiring:
  - 280 t/h steam, originally produced by Oil Boilers
  - 30 MWe electric power, originally imported from the grid
- Plant shut down in 2009. Necessary actions to restart operations are aimed at:
  - Reducing energy costs
  - Guaranteeing feedstock supply at low price
  - Introducing new technologies

### ► EuralEnergy (created in 2013):

- New Cogeneration Plant supplying steam and power to Eurallumina plant






This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Introduction

### ► EuralEnergy New Cogeneration Plant









This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Plot area



-  EA area
-  DEMI water area
-  EE.
-  Cogen area
-  Coal handling area
-  Belt conveyor

No additional plot area required for coal storage





*This project is co-financed by the European Union and the Republic of Turkey*

*Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir*

Technical Assistance for Better Air Quality by  
Transposing the Large Combustion Plants  
Directive (TR2010/0327.04-01/001)

## Scope of work (AmecFW)

### ► Feasibility study (Power Division)

- Technology comparison (CFB vs PC boiler)
- Steam cycle and steam turbine configuration definition
- Cost Estimate  $\pm$  30%

### ► Basic Design (Power Division)

- Technical documentation preparation
- Duty Specification for quotation (main equipment) to support a  $\pm$  15% estimate
- Support to EuralEnergy (techno-economic data) to ask for a soft loan financing scheme

### ► Support for permitting (Environmental Division)

- Plant construction: Environmental Impact Assessment (including final project design, pollutants dispersion, noise and landscape conservation studies)
- Plant operation: Environmental authorizations (AIA)





## Technical features – Feasibility Study

- ▶ The techno-economic analysis proved that the CFB boiler is preferred to the PC.

|             | PC    | CFB  | $\Delta$ (PC-CFB) |
|-------------|-------|------|-------------------|
| CAPEX (M€)  | 103.3 | 95.3 | +8.0              |
| OPEX (M€/y) |       |      | -0.7              |

The extra capital expenditure has a Pay-back time of 11 years (too high to select the PC boiler)

- ▶ Steam cycle configuration

EuralEnergy selected a simple steam cycle configuration, excluding more efficient and expensive solutions (e.g. higher Steam Turbine admission pressure) aimed at:

- ▶ Minimizing CAPEX
- ▶ Optimizing EE export to the grid






This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

# Technical features – Basic Design







This project is co-financed by the European Union and the Republic of Turkey


Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

# Technical features – Basic Design

## Sulfur Retention vs. Ca/S Mole Ratio

*For example only – Not a design guideline*





This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Evolution of the emissions regulation

- ▶ Emission limits for the main pollutants from coal-fired boiler in new plants:

|                         | DM 12/7/1990 | Dlgs 152/06 | EU 2010/75 | Dlgs 46/14 |
|-------------------------|--------------|-------------|------------|------------|
| <b>SOx</b>              | 1700         | 200         | 200        | <b>100</b> |
| <b>NOx</b>              | 650          | 200         | 200        | <b>100</b> |
| <b>Particulate (PM)</b> | 50           | 30          | 20         | <b>20</b>  |

*Emissions in mg/Nm<sup>3</sup>, dry @ 6% O<sub>2</sub>*

Plant Basic Design

- ▶ The gaseous emission limits require the adoption of advanced technologies, with high removal efficiency of SOx, NOx, Particulate.
- ▶ The plant shall be designed and realized considering the new emission limits set by the Dlgs 46/14 .





*This project is co-financed by the European Union and the Republic of Turkey*

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Impact of the new emission limits

- ▶ The Basic Design has been developed in collaboration with AmecFW GPG, targeted to the current emission limit regulations (March 2014):
  - ▶ SO<sub>x</sub>: 200 mg/Nm<sup>3</sup>, dry @ 6% O<sub>2</sub> → Fluid Bed, with Ca/S ratio = 3.5
  - ▶ NO<sub>x</sub>: 200 mg/Nm<sup>3</sup>, dry @ 6% O<sub>2</sub> → SNCR (TBC)
  - ▶ Particulate: 20 mg/Nm<sup>3</sup>, dry @ 6% O<sub>2</sub> → Bagfilter
  - ▶ Ammonia slip: 5 mg/Nm<sup>3</sup> (BAT for SNCR applications)
  
- ▶ Two possible CFB configurations:
  - ▶ 2 passes
  - ▶ 3 passes with ammonia killer catalyst





This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Impact of the new emission limits


- ▶ Dlgs 46/2014 (in force from 11° April), receiving EU Directive 2010/75/UE
- ▶ Impacts on the CFB boiler of the new cogeneration plant
- ▶ SO<sub>x</sub>: **100 mg/Nm<sup>3</sup>**, dry @ 6% O<sub>2</sub> →
  - Still possible in the Fluid Bed with a Ca/S ratio  $\geq 4$ .
  - A combined capture (CFB + dry FGD) may be considered.
- ▶ NO<sub>x</sub>: **100 mg/Nm<sup>3</sup>**, dry @ 6% O<sub>2</sub> →
  - Border-line between SNCR and SCR technology.
  - AmecFW GPG identifies a potential operating issue with SCR (high dust operation).
  - SNCR technology is selected.
  - The 3rd pass on the flue gas path is necessary.





## Impact of the new emission limits

- ▶ Impacts on the authorization procedures for the existing Oil Boilers (only for emergency operation):
  - ▶ SO<sub>x</sub>: from **1700 mg/Nm<sup>3</sup>** to **850 mg/Nm<sup>3</sup>**, dry @ 3% O<sub>2</sub>
  - ▶ NO<sub>x</sub>: from **650 mg/Nm<sup>3</sup>** to **450 mg/Nm<sup>3</sup>**, dry @ 3% O<sub>2</sub>
  - ▶ PM: from **50 mg/Nm<sup>3</sup>** to **25 mg/Nm<sup>3</sup>**, dry @ 3% O<sub>2</sub>





This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Comparison Summary (Oil vs CFB boilers)

### ► Technical parameters:

| MAXIMUM CAPACITY PARAMETERS          | EXISTING OIL BOILERS | NEW CFB BOILER (CHP) |
|--------------------------------------|----------------------|----------------------|
|                                      | Ante operam          | Post operam          |
| THERMAL POWER (MWth)                 | 240                  | 285                  |
| GROSS STEAM PRODUCTION (MM TON/YEAR) | 3.2                  | 3.2                  |
| GROSS ELECTRIC POWER (MWe)           | 0                    | 51.5                 |
| INTERNAL CONSUMPTION                 | 4.5 (import)         | 7                    |
| EXPORT TO ELECTRIC GRID              | --                   | 14                   |
| TO EURALLUMINA                       | --                   | 30                   |
| ENERGY EFFICIENCY INDEX              | 90%                  | 96%                  |
| FUEL                                 | OIL                  | COAL                 |





This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Comparison Summary (Oil vs CFB boilers)

### ► Environmental parameters (gaseous pollutants emission):

| MAXIMUM CAPACITY PARAMETERS | EXISTING OIL BOILERS | NEW CFB BOILER (CHP) | PERCENT REDUCTION |
|-----------------------------|----------------------|----------------------|-------------------|
|                             | Ante operam          | Post operam          |                   |
| SO <sub>2</sub> (TON/YEAR)  | 3075                 | 320                  | 90%               |
| NO <sub>x</sub> (TON/YEAR)  | 1570                 | 320                  | 80%               |
| PARTICULATE (TON/YEAR)      | 125                  | 64                   | 49%               |

*Yearly emissions to atmosphere (t/y) in normal operating conditions (8760 hours).*






This project is co-financed by the European Union and the Republic of Turkey

Bu Proje Avrupa Birliği ve Türkiye Cumhuriyeti tarafından finanse edilmektedir

Technical Assistance for Better Air Quality by Transposing the Large Combustion Plants Directive (TR2010/0327.04-01/001)

## Economic Estimate and Schedule


- ▶ Investment plan for new power station and revamping of existing alumina plant: **185 M€**
- ▶ Permitting process under finalization
- ▶ Overall project schedule:







# Permit History





*This project is co-financed by the European Union and the Republic of Turkey*

**Bu Proje Avrupa Birliđi ve Trkiye Cumhuriyeti tarafından finanse edilmektedir**

Technical Assistance for Better Air Quality by  
Transposing the Large Combustion Plants  
Directive (TR2010/0327.04-01/001)

